

कार्यालय अनुविभागीय अधिकारी  
लोक निर्माण विभाग (भवन/सड़क), सरायपाली-उपसंभाग  
जिला - महासमुन्द (छ.ग.)

ज्ञाप क्रमांक  
प्रति,

89L/शिल्प

सरायपाली, दिनांक 26/06/2023

प्राचार्य  
केन्द्रीय विद्यालय  
सरायपाली (छ.ग.)


विषय :- केन्द्रीय विद्यालय सरायपाली को सी.बी.एस.सी. संबद्धता (CBSE Affiliation upto Secondary Level) जारी रखने हेतु विद्यालय अस्थाई भवन की संरचनात्मक एवं सुरक्षा प्रमाण-पत्र/School Building Safety Certificate जारी करने हेतु अनुरोध के संदर्भ में।

संदर्भ :- आपका पत्रांक क्रं. फ-1-10/केवि-सरायपाली/2023-24/429 दिनांक 21.06.2023।

—00—

उपरोक्त विषयांतर्गत संदर्भित पत्रानुसार चाही गई जानकारी तैयार कर आपकी ओर सादर प्रेषित है।

सहपत्र :- उपरोक्तानुसार,

  
अनुविभागीय अधिकारी  
लो.नि.वि.(भ/स) सरायपाली-उपसंभाग  
सरायपाली (छ.ग.)

**BUILDING SAFETY CERTIFICATE**

NO.


Dated:

Certified that the existing building Govt. Girls Higher Secondary School at Saraipali comprised of NO basement(s) and NO (upper floors) owned/occupied by Kendriya Vidyalay Saraipali have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Public Works Department on 26.06.2023 in the presence of K.V.Office Staff (Teacher) and that the building/premises is fit for occupancy upto classes X (X/XII) with effect from 01.04.2023 for a period of 01 (One) Years in accordance with rule and subject to compliance of the specific conditions ad appended.

1. It is advised that roof Grading should be done in the entire building, water stagnation at roof can cause spalling of concrete.
2. All Exit to be kept open during school hours.
3. Repaires to be made as instructed to K.V.office staff during inspection.

Issued on 26.03.2023 At Saraipali by

Signature with Seal :



Name : **K. Vignesh Kumar**

Designation : **Sub Divisional Officer**

Name & Address fo Department/Office: **Public Work Department (B/R) Sub Div. Saraipali**